



BREAKERS ARE MECHANICALLY INTERLOCKED BY A WALKING BEAM

NOTES

☐ EMERGENCY CAM-LOCK CONNECTION OPTION

| AMPS | BONDING JUMPER |  |
|------|----------------|--|
|      | MIN. SIZE      |  |
| 60   | 8 AWG          |  |
| 100  | 6 AWG          |  |
| 200  | 4 AWG          |  |
| 400  | 1/0 AWG        |  |
| 600  | 2/0 AWG        |  |
| 800  | 2/0 AWG        |  |
| 1200 | 3/0 DLO        |  |
| 1600 | 3/0 DLO        |  |
| 2000 | 313 DLO        |  |
| 2500 | 313 DLO        |  |
| 3000 | 313 DLO        |  |



9900 TWIN LAKES PARKWAY  
 CHARLOTTE, NC 28269  
 704-596-5617  
 PSICONTROLSOLUTIONS.COM

SE RATED BREAKER-BREAKER TRANSFER SWITCH

| REV | DESCRIPTION      | DATE    | DRAWN       | S.RICHARDSON | CHECKED              |
|-----|------------------|---------|-------------|--------------|----------------------|
| 0   | ORIGINAL RELEASE | 3/15/17 |             |              |                      |
| 1   |                  |         | SUP. NO.    |              | DRAWING TYPE         |
| 2   |                  |         | SUP. BY NO. |              | ELECTRICAL SCHEMATIC |
| 3   |                  |         | PANEL NO.   |              | DRAWING NO.          |
| 4   |                  |         | BUL. NO.    |              | ES11BTS2A            |
| 5   |                  |         | GROUP NO.   |              |                      |
| 6   |                  |         | ORDER NO.   |              |                      |

DATE

CUSTOMER APPROVAL