


AMPS	BONDING JUMPER	
	MIN. SIZE	
60	8 AWG	
100	6 AWG	
200	4 AWG	
400	1/0 AWG	
600	2/0 AWG	
800	2/0 AWG	
1200	3/0 DLO	
1600	3/0 DLO	
2000	313 DLO	
2500	313 DLO	
3000	313 DLO	



9900 TWIN LAKES PARKWAY
 CHARLOTTE, NC 28269
 704-596-5617
 PSICONTROLSOLUTIONS.COM

3E RATED BREAKER-BREAKER TRANSFER SWITCH			
REV	DESCRIPTION	DATE	DRAWN S.RICHARDSON
0	ORIGINAL RELEASE	3/15/17	CHECKED
1			SUP. NO.
2			SUP. BY NO.
3			PANEL NO.
4			BUL. NO.
5			GROUP NO.
6			ORDER NO.

DRAWING TYPE
ELECTRICAL SCHEMATIC

DRAWING NO.
ES11BTS3A

SHEET 1 OF 1

DATE

CUSTOMER APPROVAL