


NOTES
 [D] ADDITIONAL OPTION FOR UL CERTIFICATION
 [Z] PHASE REVERSAL PROTECTION OPTION

AMP.	CAM-LOCK QTY
400	1
800	2
1200	3
1600	4
2000	5
2400	6
2800	7
3200	8
4000	10

fuse SIZING
 FU1

VAC	A
208/240	0.6A
480	0.3A

GENERATOR TAP BOX					
REV	DESCRIPTION	DATE	DRAWN	ENGR. APP.	
A	ORIGINAL RELEASE	10/2/14	CHECKED J.RAY		SUPR. APP.
B			SUP. NO.		
C			SUP. BY NO.		
D			PANEL NO.		
E			BUL. NO.		
F			GROUP NO.		
G			ORDER NO.		



9900 TWIN LAKES PARKWAY
 CHARLOTTE, NC 28269
 704-596-5617
 PSICONTROLSOLUTIONS.COM

ES11GTB5

COMPUTER GENERATED TRACING