



SPECIFICATIONS


MAX VOLTAGE - 600VAC 3Ø  
RATED CURRENT - 400 A  
STANDARDS - UL1008  
ENCLOSURE RATING - NEMA 1  
REF. ES100145SE3  
DURABILITY - 6050 CYCLES  
EST SHIPPING WEIGHT - 350LBS




TOP VIEW




FRONT VIEW




SIDE VIEW



BOTTOM VIEW



SIDE VIEW




DIMETRIC VIEW




9900 TWIN LAKES PARKWAY  
CHARLOTTE, NC 28269  
704-596-5617  
PSICONTROLSOLUTIONS.COM


400A SE-RATED 3-POLE NEMA 1 MANUAL TRANSFER SWITCH					
REV	DESCRIPTION	DATE	DRAWN	C. JUNG	
0	ORIGINAL RELEASE	9/28/17	CHECKED		
1	FUSES MOVED	7/9/21	SUP. NO		DRAWING TYPE
2	LIGHTS ADDED	9/7/21	SUP. BY NO		DIMENSIONAL
3	HARD BUS ADDED	2/8/22	PANEL NO		DRAWING NUMBER
			BUL. NO		STS400N1SE3
			GROUP NO		
			ORDER NO		



FRONT VIEW  
DOOR REMOVED



FRONT VIEW  
ENCLOSURE REMOVED



DIMETRIC VIEW  
DOOR REMOVED

NOTE: FUSES PROVIDED IF PURCHASED  
480-600VAC : LPJ-400SP



9900 TWIN LAKES PARKWAY  
CHARLOTTE, NC 28269  
704-596-5617  
PSICONTROLSOLUTIONS.COM

400A SE-RATED 3-POLE NEMA 1 MANUAL TRANSFER SWITCH					
REV	DESCRIPTION	DATE	DRAWN	C. JUNG	
0	ORIGINAL RELEASE	9/28/17	CHECKED		
1	FUSES MOVED	7/9/21	SUP. NO		DRAWING TYPE
2	LIGHTS ADDED	9/7/21	SUP. BY NO		DIMENSIONAL
3	HARD BUS ADDED	2/8/22	PANEL NO		DRAWING NUMBER
			BUL. NO		STS400N1SE3
			GROUP NO		
			ORDER NO		