



SPECIFICATIONS

MAX VOLTAGE - 600VAC 3Ø
RATED CURRENT - 800 A
STANDARDS - UL508A
ENCLOSURE RATING - NEMA 4X
REF. ES100145SE
DURABILITY - 3550 CYCLES
EST SHIPPING WEIGHT - 650LBS




TOP VIEW


36.00
ENCLOSURE WIDTH




FRONT VIEW




SIDE VIEW



DIMETRIC VIEW



SIDE VIEW



BOTTOM VIEW


RECEPTACLE/COVER COLOR SCHEME

	L1	L2	L3	N	GND
240VAC	BLK	RED	BLU	WHT	GRN
480VAC	BRN	ORG	YEL	WHT	GRN




9900 TWIN LAKES PARKWAY
CHARLOTTE, NC 28269
704-596-5617
PSICONTROLSOLUTIONS.COM


800A SE-RATED 3-POLE NEMA 4X MANUAL TRANSFER SWITCH					
REV	DESCRIPTION	DATE	DRAWN C. JUNG		
0	ORIGINAL RELEASE	1/30/14	CHECKED		
1	FUSES MOVED	8/19/21	SUP. NO		
2	LIGHTS ADDED	9/8/21	SUP. BY NO		
			PANEL NO		
			BUL. NO		
			GROUP NO		
			ORDER NO		
			DRAWING TYPE		
			DIMENSIONAL		
			DRAWING NUMBER		
			STS800N4XSE3		



FRONT VIEW
DOOR REMOVED



FRONT VIEW
ENCLOSURE REMOVED



DIMETRIC VIEW
DOOR REMOVED

NOTE: FUSES PROVIDED IF PURCHASED
208-600VAC : KRP-C-800SP



9900 TWIN LAKES PARKWAY
CHARLOTTE, NC 28269
704-596-5617
PSICONTROLSOLUTIONS.COM

800A SE-RATED 3-POLE NEMA 4X MANUAL TRANSFER SWITCH					
REV	DESCRIPTION	DATE	DRAWN	C. JUNG	
0	ORIGINAL RELEASE	9/17/17	CHECKED		
1	FUSES MOVED	8/19/21	SUP. NO		DRAWING TYPE
2	LIGHTS ADDED	9/8/21	SUP. BY NO		OUTLINE
			PANEL NO		DRAWING NUMBER
			BUL. NO		STS800N4XSE3
			GROUP NO		
			ORDER NO		