




TOP VIEW



SIDE VIEW




FRONT VIEW




SIDE VIEW


PERMANENT CONNECTIONS  
L1,L2,L3,N-(2) #2-750MCM  
G-#6-350MCM




FRONT VIEW  
DOOR REMOVED




SIDE VIEW  
INTERIOR



BOTTOM VIEW  
DOOR REMOVED



TRIMETRIC VIEW  
INTERIOR



BOTTOM VIEW

RECEPTACLE COLOR SCHEME

	L1	L2	L3	N	GND
240V	BLK	RED	BLU	WHT	GRN
480V	BRN	ORG	YEL	WHT	GRN
600V	BLK	BLK	BLK	WHT	GRN

NOTES

1. ENCLOSURE RATED NEMA 3R
2. TYPE 316 STAINLESS STEEL AVAILABLE
3. 3-PHASE, 4-WIRE SHOWN
4. MAX VOLTAGE-600VAC
5. ASSEMBLY IS UL508A LISTED

800A BOTTOM ENTRY GENERATOR TAP BOX

REV	DESCRIPTION	DATE	DRAWN	S.RICHARDSON	
0	ORIGINAL RELEASE	5/25/16	CHECKED	J.RAY	
			SUP. NO		DRAWING TYPE
			SUP. BY NO		DIMENSIONAL
			PANEL NO		DRAWING NUMBER
			BUIL. NO		PL800GTBDDM
			GROUP NO		
			ORDER NO		



9900 TWIN LAKES PARKWAY  
CHARLOTTE, NC 28269  
704-596-5617  
PSICONTROLSOLUTIONS.COM