




LEFT SIDE




TOP VIEW



FRONT VIEW



RIGHT SIDE




FRONT VIEW (DOORS REMOVED)


PERMANENT CONNECTIONS NEUTRAL (2) #2-600 MCM  
PERMANENT CONNECTIONS GROUND (1) #6-350 MCM

PERMANENT CONNECTIONS LINE (2) 400-500 MCM


ROTARY CIRCUIT BREAKER HANDLE MOUNTED TO SWING PANEL



INTERIOR SIDE VIEW




BOTTOM VIEW



BOTTOM VIEW (DOOR OPEN)

ANGLED CAM-LOK RECEPTACLES



INTERIOR TRIMETRIC VIEW

**RECEPTACLE COLOR SCHEME**

|      | L1  | L2  | L3  | N   | GND |
|------|-----|-----|-----|-----|-----|
| 240V | BLK | RED | BLU | WHT | GRN |
| 480V | BRN | ORG | YEL | WHT | GRN |
| 600V | BLK | BLK | BLK | WHT | GRN |

**NOTES**

1. ENCLOSURE RATED NEMA 3R
2. TYPE 316 STAINLESS STEEL AVAILABLE
3. 3Ø, 4-WIRE SHOWN. ALTERNATE CONFIGURATIONS AVAILABLE
4. MAX VOLTAGE- 600VAC
5. STANDARDS - UL508A

**600A GENERATOR TAP BOX WITH MAIN CIRCUIT BREAKER**

| REV | DESCRIPTION      | DATE    | DRAWN: D. DENNY |                |
|-----|------------------|---------|-----------------|----------------|
| 0   | ORIGINAL RELEASE | 3/28/18 | CHECKED:        |                |
|     |                  |         | SUP. NO:        | DRAWING TYPE   |
|     |                  |         | SUP. BY NO:     | DIMENSIONAL    |
|     |                  |         | PANEL NO:       | DRAWING NUMBER |
|     |                  |         | BUL. NO:        | GTBECB600      |
|     |                  |         | GROUP NO:       |                |
|     |                  |         | ORDER NO:       |                |



9900 TWIN LAKES PARKWAY  
CHARLOTTE, NC 28269  
704-596-5617  
PSICONTROLSOLUTIONS.COM