




TOP VIEW



SIDE VIEW




FRONT VIEW




SIDE VIEW


PERMANENT CONNECTIONS
L1,L2,L3,N-(4) #2-750MCM
G-#6-350MCM




FRONT VIEW
DOOR REMOVED




SIDE VIEW
INTERIOR



BOTTOM VIEW
DOOR REMOVED



TRIMETRIC VIEW
INTERIOR



BOTTOM VIEW

RECEPTACLE COLOR SCHEME

	L1	L2	L3	N	GND
240V	BLK	RED	BLU	WHT	GRN
480V	BRN	ORG	YEL	WHT	GRN
600V	BLK	BLK	BLK	WHT	GRN

NOTES

1. ENCLOSURE RATED NEMA 3R
2. TYPE 316 STAINLESS STEEL AVAILABLE
3. 3-PHASE, 4-WIRE SHOWN
4. MAX VOLTAGE-600VAC
5. ASSEMBLY IS cETLus 1008 LISTED



1600A BOTTOM ENTRY GENERATOR TAP BOX

REV	DESCRIPTION	DATE	DRAWN	S.RICHARDSON
0	ORIGINAL RELEASE	5/25/16	CHECKED	J.RAY
			SUP. NO	
			SUP. BY NO	
			PANEL NO	
			BUIL. NO	
			GROUP NO	
			ORDER NO	

DRAWING TYPE
DIMENSIONAL

DRAWING NUMBER
PL1600GTBDDM

9900 TWIN LAKES PARKWAY
CHARLOTTE, NC 28269
704-596-5617
PSICONTROLSOLUTIONS.COM