





SPECIFICATIONS


MAX VOLTAGE - 600VAC
CURRENT RATING - 800A
ENCLOSURE RATING - NEMA 3R
REF. - ES3WMTS
EST. SHIPPING WEIGHT - 650LBS

- NOTES:
- 1. GENERATOR BREAKERS ARE MECHANICALLY INTERLOCKED WITH A KIRK KEY PAIR, ONLY ONE CAN BE ENERGIZED AT A TIME.
 - 2. TEMPORARY GENERATOR CAM-LOCK ACCESS DOOR CAN'T BE OPENED UNLESS FRONT DOOR IS OPENED FIRST.
 - 3. LOAD BANK CAM-LOCK ACCESS DOOR CAN'T BE OPENED UNLESS INTERIOR DOOR IS OPENED FIRST, ENSURING ALL BREAKERS ARE OFF AND CAM-LOCKS ARE DE-ENERGIZED.



RECEPTACLE COLOR SCHEME

	L1	L2	L3	N	GND
240V	BLK	RED	BLU	WHT	GRN
480V	BRN	ORG	YEL	WHT	GRN
600V	BLK	BLK	BLK	WHT	GRN




9900 TWIN LAKES PARKWAY
CHARLOTTE, NC 28269
704-596-5617
PSICONTROLSOLUTIONS.COM


800A NEMA 3R 3-WAY MANUAL TRANSFER SWITCH

REV	DESCRIPTION	DATE	DRAWN: C. JUNG	
0	ORIGINAL RELEASE	12/28/21	CHECKED:	
1	BUSBAR CHANGED	03/28/22	SUP. NO:	
			SUP. BY NO:	
			PANEL NO:	
			BUL. NO:	
			GROUP NO:	
			ORDER NO:	


DRAWING TYPE	DIMENSIONAL
DRAWING NUMBER	3WMTS800N3R



FRONT VIEW
(DOOR REMOVED)



FRONT VIEW
(ENCLOSURE REMOVED)



DIMETRIC VIEW
(DOOR REMOVED)



9900 TWIN LAKES PARKWAY
CHARLOTTE, NC 28269
704-596-5617
PSICONTROLSOLUTIONS.COM

800A NEMA 3R 3-WAY MANUAL TRANSFER SWITCH

REV	DESCRIPTION	DATE	DRAWN: C. JUNG	
0	ORIGINAL RELEASE	12/28/21	CHECKED:	
1	BUSBAR CHANGED	03/28/22	SUP. NO:	
			SUP. BY NO:	
			PANEL NO:	
			BUL. NO:	
			GROUP NO:	
			ORDER NO:	

DRAWING TYPE
DIMENSIONAL

DRAWING NUMBER
3WMTS800N3R